


280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

Also admitted in Massachusetts

October 31, 2013

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051



Re: **EM-VER-070-130920 – Route 80, Killingworth, Connecticut
Completion of Construction Activity**

Dear Ms. Bachman:

The purpose of this letter is to notify the Siting Council that construction activity associated with the above-referenced Cellco Partnership d/b/a Verizon Wireless telecommunications facility has been completed.

If you have any questions or need any additional information regarding this facility please do not hesitate to contact me.

Sincerely,

Kenneth C. Baldwin



Law Offices

BOSTON

PROVIDENCE

HARTFORD

NEW LONDON

STAMFORD

WHITE PLAINS

NEW YORK CITY


ALBANY

SARASOTA

www.rc.com

Copy to:
Sandy M. Carter

12506247-v1



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

October 9, 2013

Kenneth C. Baldwin, Esq.
Robinson & Cole LLP
280 Trumbull Street
Hartford, CT 06103

RE: **EM-VER-070-130920** – Cellco Partnership d/b/a Verizon Wireless notice of intent to modify an existing telecommunications facility located at Route 80, Killingworth, Connecticut.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) hereby acknowledges your notice to modify this existing telecommunications facility, pursuant to Section 16-50j-73 of the Regulations of Connecticut State Agencies with the following conditions:

- Any deviation from the proposed modification as specified in this notice and supporting materials with the Council shall render this acknowledgement invalid;
- Any material changes to this modification as proposed shall require the filing of a new notice with the Council;
- Within 45 days after completion of construction, the Council shall be notified in writing that construction has been completed;
- The validity of this action shall expire one year from the date of this letter; and
- The applicant may file a request for an extension of time beyond the one year deadline provided that such request is submitted to the Council not less than 60 days prior to the expiration.

The proposed modifications including the placement of all necessary equipment and shelters within the tower compound are to be implemented as specified here and in your notice dated September 18, 2013. The modifications are in compliance with the exception criteria in Section 16-50j-72 (b) of the Regulations of Connecticut State Agencies as changes to an existing facility site that would not increase tower height, extend the boundaries of the tower site, increase noise levels at the tower site boundary by six decibels, and increase the total radio frequencies electromagnetic radiation power density measured at the tower site boundary to or above the standard adopted by the State Department of Environmental Protection pursuant to General Statutes § 22a-162. This facility has also been carefully modeled to ensure that radio frequency emissions are conservatively below State and federal standards applicable to the frequencies now used on this tower.

This decision is under the exclusive jurisdiction of the Council. Please be advised that the validity of this action shall expire one year from the date of this letter. Any additional change to this facility will require explicit notice to this agency pursuant to Regulations of Connecticut State Agencies Section 16-50j-73. Such notice shall include all relevant information regarding the proposed change with cumulative worst-case modeling of radio frequency exposure at the closest point of uncontrolled access to the tower base, consistent with Federal Communications Commission, Office of Engineering and Technology, Bulletin 65. Thank you for your attention and cooperation.

Very truly yours,

Melanie A. Bachman
Acting Executive Director

MAB/CDM/jb

c: The Honorable Catherine Iino, First Selectman, Town of Killingworth
Cathie Jefferson, Zoning Enforcement Officer, Town of Killingworth
Crown Castle





STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

September 24, 2013

The Honorable Catherine Iino
First Selectman
Town of Killingworth
Town Office Building
323 Route 81
Killingworth, CT 06419-1298

RE: **EM-VER-070-130920** – Cellco Partnership d/b/a Verizon Wireless notice of intent to modify an existing telecommunications facility located at Route 80, Killingworth, Connecticut.

Dear First Selectman Iino:

The Connecticut Siting Council (Council) received a request to modify an existing telecommunications facility, pursuant to Regulations of Connecticut State Agencies Section 16-50j-72, a copy of which has already been provided to you.

If you have any questions or comments regarding the proposal, please call me or inform the Council by October 8, 2013.

Thank you for your cooperation and consideration.

Very truly yours,

Melanie Bachman
Acting Executive Director

MB/jb

c: Cathie Jefferson, Zoning Enforcement Officer, Town of Killingworth

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

Also admitted in Massachusetts

September 18, 2013

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051



Re: **Notice of Exempt Modification – Generator Fuel Tank Upgrade
Route 80, Killingworth, Connecticut**

Dear Ms. Bachman:

Cellco Partnership d/b/a Verizon Wireless (“Cellco”) currently maintains a wireless telecommunications facility at the above-referenced address. Cellco’s facility consists of antennas on the existing 160-foot tower, a shelter housing its radio equipment and a propane-fueled back-up generator, and a 500 gallon propane tank, all located within the existing fenced facility compound.

In an effort to improve the reliability of the back-up power supply and further enhance overall network reliability, Cellco intends to modify its Route 80 facility by replacing the existing 500 gallon propane tank with a new 1,000 gallon propane tank, located in the northeasterly corner of the facility compound. (See attached Compound Plan).

Please accept this letter as notification pursuant to R.C.S.A. § 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this letter is being sent to Catherine Iino, First Selectwoman of the Town of Killingworth. A copy of this letter is also being sent to 14 Route 80 LLC, the owners of the property on which the tower is located.

The planned modifications to the Cellco facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2).



Law Offices

BOSTON

PROVIDENCE

HARTFORD

NEW LONDON

STAMFORD

WHITE PLAINS

NEW YORK CITY

ALBANY

SARASOTA

www.rc.com

12371201-v1

ROBINSON & COLE^{LLP}

Melanie A. Bachman
September 18, 2013
Page 2

1. The proposed modifications will not result in an increase in the height of the existing tower.
2. The 1,000 gallon propane tank will be located within the limits of the existing fenced compound. The modifications, therefore, will not require the extension of the site boundary.
3. The proposed modifications will not increase noise levels at the facility by six decibels or more.
4. The installation of a new 1,000 gallon propane tank will not change, in any way, radio frequency (RF) emissions at the facility.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The proposed modifications will not involve any modifications to the existing tower, therefore, a structural report has not been submitted as part of this filing.

For the foregoing reasons, Cellco respectfully submits that the proposed modifications to the above-referenced telecommunications facility constitutes an exempt modification under R.C.S.A. § 16-50j-72(b)(2).

Sincerely,



Kenneth C. Baldwin

Enclosures

Copy to:

Catherine Iino, Killingworth First Selectwoman
14 Route 80 LLC
Sandy M. Carter



Cellco Partnership




d.b.a. **verizon**wireless

WIRELESS COMMUNICATIONS FACILITY

KILLINGWORTH


14 CONNECTICUT ROUTE 80

KILLINGWORTH, CT 06419



PROJECT SUMMARY	
SITE NAME:	KILLINGWORTH
SITE ADDRESS:	14 CONNECTICUT ROUTE 80 KILLINGWORTH, CT 06419
CELLCO PARTNERSHIP/TENANT:	CELLCO PARTNERSHIP 4330 CELLCO PARTNERSHIP WIRELESS 99 EAST RIVER DRIVE EAST HARTFORD, CT 06108
CONTACT PERSON:	SANDY CARTER CELLCO PARTNERSHIP (860) 803-8219
ENGINEER:	CENTEK ENGINEERING, INC. 63-2 NORTH BRANFORD ROAD BRANFORD, CT 06405 (203) 488-0580
TOWER COORDINATES:	LATITUDE: 41°-21'-26.43" LONGITUDE: 72°-31'-11.82" (REFERENCED FROM CSC DATABASE)

SHEET INDEX	
SHT. NO.	DESCRIPTION
T-1	TITLE SHEET
C-1	COMPOUND PLAN




SITE DIRECTIONS	
FROM: 99 EAST RIVER DRIVE EAST HARTFORD, CONNECTICUT	TO: 14 CONNECTICUT ROUTE 80 KILLINGWORTH, CT
1. Head southwest on E River Dr toward Pikes St	
2. Turn right to merge onto CT-2 E toward Norwich	
3. Turn right onto the U.S. 5 S/Connecticut 15 S	
4. Merge onto US-5 S	
5. Take exit 26 to merge onto I-91 S toward New Haven/New York City	
6. Take exit 26 to merge onto CT-9 S toward Middletown/Old Saybrook	
7. Continue onto CT-17 S/CT-9 S	
8. Continue onto CT-9 S	
9. Take exit 5 for CT-80 toward Deep River/Killing Worth	
10. Turn right onto CT-80 W/Elm St	
11. Turn right onto CT-80 W/Winthrop Rd Continue to follow CT-80 W	
12. Destination will be on the left	

PROJECT SCOPE
1. THE PROPOSED SCOPE OF WORK GENERALLY INCLUDES THE INSTALLATION OF A OF CELLCO PARTNERSHIP 1000 GAL. PROPANE TANK ON A 5'x18' CONC. PAD WITHIN THE EXISTING FENCED COMPOUND AREA, AND REMOVAL OF EXISTING CELLCO PARTNERSHIP'S 500 GAL. PROPANE TANK AND ASSOCIATED CONCRETE PAD.

REV.	DATE	BY	CHK'D	DESCRIPTION
1	09/17/13	TMD	DMD	ISSUED FOR CSC - CLIENT REVIEW
0	06/06/13	TMD	DMD	ISSUED FOR CSC - CLIENT REVIEW

REV.	DATE	BY	CHK'D	DESCRIPTION
1	09/17/13	TMD		ISSUED FOR CSC - CLIENT REVIEW
0	08/06/13	TMD		ISSUED FOR CSC - CLIENT REVIEW





CENTEK engineering
 Confined on Solutions™
 (203) 488-0580
 (203) 488-8587 Fax
 63-2 North Branford Road, Branford, CT 06405
 www.Centek.com

KILLINGWORTH
 Cellco Partnership d/b/a Verizon Wireless
 14 CONNECTICUT ROUTE 80
 KILLINGWORTH, CT 06419
 DATE: 08/06/13
 SCALE: AS NOTED
 JOB NO. 12010.010

COMPOUND PLAN

C-1
 DWG. 2 OF 2



1 COMPOUND PLAN - PROPOSED
 SCALE: 1" = 20'-0"